



Absence-of-voltage detector

913-VAT1

SAM Outillage

10 rue Camille de Rochetaillée
42000 Saint-Etienne - France

RCS Saint-Etienne B 338 002 231 | SAS au capital de 8 189 583 €

<https://www.sam-outillage.com/>

Photos and texts not contractually binding. Do not litter. Document generated on 2024-04-27 06:30:03





DESCRIPTION

Absence-of-voltage detector

SAFETY: IP65 casing. PRACTICAL. Automatic switchovers to wake-up and standby modes.

LOW VOLTAGE Bipolar Voltage Detector - VAT

- Full integrated self-test.
- Voltage test up to 690VAC (16 2 / 3-800Hz) / 750VDC.
- Unipolar phase test.
- Phase order control up to 400Hz.
- Removable tip and cord.
- Supplied with cords.

- Indication by red light of dangerous voltage.
- Autonomy of 7000 measurements of 10s.
- Dimensions: 163 x 64 x 40 mm.
- Conditions of use: from -15 ° C to + 45 ° C.

SAM Outillage

10 rue Camille de Rochetaillée
42000 Saint-Etienne - France

RCS Saint-Etienne B 338 002 231 | SAS au capital de 8 189 583 €

<https://www.sam-outillage.com/>

Photos and texts not contractually binding. Do not litter. Document generated on 2024-04-27 06:30:03



CAT IV - 600V

STANDARDS / DIRECTIVES

2011/65/UE, 2014/30/CE, EN 61326-1, EN 61243-3

SPECIFIC DATA

Designation	NO VOLTAGE DETECTOR
Sales reference	913-VAT1
Weight (g)	330
Dim mm	163 x 34 x 40mm
Steel 80	12V - 690V/AC ; 12V - 750V/DC
Steel 200	DC, 16 2/3 at 800Hz
Steel 80	Above 50V (45-65Hz) above 150V (16 2/3-45Hz)
Steel 160	100 Ohms typically (150 Ohms max.)
A maxi mm	2kOhms,60kOhms,300kOhms
Guarantee	Up to 690V

Guarantee applied

M1 | SAM Equipment and Machine Guarantee:

Guarantee for a limited period, covering technical tools, devices and machines used under normal conditions. The length is given by the number after the letter M: 1 to 5 years

[>> Find out more](#)

SAM Outillage

10 rue Camille de Rochetaillée
42000 Saint-Etienne - France

RCS Saint-Etienne B 338 002 231 | SAS au capital de 8 189 583 €

<https://www.sam-outillage.com/>

